

10A NCAC 14E .0210 CORRIDORS

The width of corridors shall be sufficient to allow for patient evacuation by stretcher, but in no case shall patient-use corridors be less than 60 inches.

*History Note: Authority S.L. 2023-14, s. 2.4;
 Emergency Adoption Eff. July 18, 2023.*