

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/21/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 345458	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/20/2013
--	---	--	---

NAME OF PROVIDER OR SUPPLIER PEAK RESOURCES - TREYBURN	STREET ADDRESS, CITY, STATE, ZIP CODE 2059 TORREDGE ROAD DURHAM, NC 27712
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>This facility is in compliance with the requirements of 42 CFR part 483, Subpart B, for Long Term Care facilities. Event ID JVHM11.</p>	F 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 345458	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 04/18/2013
--	--	--	--

NAME OF PROVIDER OR SUPPLIER PEAK RESOURCES - TREYBURN	STREET ADDRESS, CITY, STATE, ZIP CODE 2059 TORREDGE ROAD DURHAM, NC 27712
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X6) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 046 SS=D	<p>NFPA 101 LIFE SAFETY CODE STANDARD</p> <p>Emergency lighting of at least 1½ hour duration is provided in accordance with 7.9. 19.2.9.1.</p> <p>This STANDARD is not met as evidenced by: 42 CFR 483.70(a) By observation on 4/18/13 at approximately noon the following exit discharge illumination was observed as non-compliant, specific findings include, no light fixtures along the 500 hall exit discharge path to the public way. Lighting must be arranged to provide light from the exit discharge leading to the public way (parking lot). The walking surfaces within the exit discharge shall be illuminated to values of at least 1 ft-candle measured at the floor. Failure of any single lighting unit does not result in an illumination level of less than 0.2 ft-candles in any designated area. NFPA 101 7.8.1.1, 7.8.1.3, and 7.8.1.4.</p>	K 046	<p><i>Preparation and/or execution of this plan of correction does not constitute admission or agreement by the provider of the truth of the facts alleged or conclusions set forth in the statement of deficiencies. The plan of correction is prepared and/or executed solely because it is required by the provision of federal and state law.</i></p> <p><i>This Plan of Correction is the facility's credible allegation of compliance.</i></p> <p>K 046</p> <p>To Correct The Deficient Practice: Emergency lighting of at least 1 ½ hour duration was provided to the 500 hall exit discharge path to the public way. The lighting was arranged to provide at least 1 ft-candle measured at the floor from the exit discharge path to the public way.</p> <p>For those with Potential to be affected An audit of all emergency lighting conducted to ensure compliance with Life Safety Code.</p> <p>Systemic Change: Maintenance director to ensure compliance of emergency lighting. The facility implemented a QA form to be completed monthly.</p> <p>Plans will be Monitored by: The results of the monthly audits will be reported to the QA&A Committee monthly x 3 months for review and recommendations.</p>	5/2/13 4/26/13
---------------	--	-------	---	-----------------------

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE  TITLE Administrator (X6) DATE 4/29/13

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.