10A NCAC 13	K .1109 is proposed for readoption with substantive changes as follows:			
10A NCAC 13	K .1109 RESIDENT CARE AREAS			
(a) Resident rooms shall meet the following requirements: A facility shall meet the following requirements for residen				
bedrooms:				
(1)	There shall be private or semiprivate rooms; private bedroom with not less than 100 square feet of			
	floor area or semi-private bedroom with not less than 80 square feet of floor area per bed shall be			
	provided;			
(2)	Infants infants and small children shall not be assigned to share a room bedroom with an adult			
	resident unless requested by residents the resident and families;			
(3)	Each resident room each bedroom shall contain at least be furnished with a bed, a mattress protected			
	by waterproof material, a mattress pad, a pillow, and a chair; one chair per resident;			
(4)	Each resident room shall have a minimum of 48 cubic feet of closet space or wardrobe for clothing			
	and personal belongings that provides security and privacy for each resident. Each resident room			
	shall be equipped with a towel rack for each individual; each bedroom shall be provided with one			
	closet or wardrobe per bed. Each closet or wardrobe shall have clothing storage space of not less			
	than 48 cubic feet per bed with one-half of this space for hanging clothes;			
(5)	Each resident each bedroom shall:			
	(A) be located at or above grade level;			
	(B) have provisions to ensure visual privacy for treatment or visiting; be provided with a			
	cubicle curtain enclosing each bed to ensure visual privacy; and			
	(C) be equipped with a towel rack for each resident;			
(6)	Artificial lighting shall be provided sufficient each bedroom shall provide lighting for treatment and			
	non-treatment needs, 50 foot-candles foot-candles for treatment, treatment needs, and 35 foot			
	eandles foot-candles for non-treatment areas; needs; and			
(7)	A room where access is through a bathroom, kitchen or another bedroom will not be approved for a			
	resident's bedroom. no resident bedroom shall be accessed through a bathroom, kitchen, or another			
	bedroom.			
(b) Bathrooms	shall meet the following requirements: A facility shall meet the following requirements for bathrooms:			
(1)	Bathroom facilities bathrooms shall be conveniently directly accessible to resident rooms. each			
	resident bedroom without going through the general corridors. One bathroom may serve up to four			
	residents and staff. residents. Minimum size of any bathroom shall be 18 square feet. The door			
	bathroom doorway shall be at least 32 inches wide. be a minimum 32-inch clear opening:			
(2)	The each bathroom shall be furnished with the following:			
	(A) <u>a</u> toilet with grab bars;			
	(B) lavatory with four inch wrist blade controls; a sink trimmed with valves that can be			
	operated without hands. If the sink is equipped with blade handles, the blade handles shall			
	10A NCAC 13 (a) Resident robedrooms:  (1)  (2)  (3)  (4)  (5)  (6)  (7)  (b) Bathrooms  (1)			

1			not be less than four inches in length. If the sink faucet depends on the building electrical
2			service for operation, the faucet must have an emergency power source or battery backup
3			capability. If the faucet has battery operated sensors, the facility shall have a maintenance
4			policy to keep extra rechargeable or non-rechargeable batteries on premises for the faucets;
5		(C)	<u>a</u> mirror;
6		(D)	soap, paper towel dispensers, and waste paper receptacle with a removable impervious
7			liner; and
8		<del>(E)</del>	water closet; and
9		<del>(F)</del> (E)	<u>a</u> tub or shower.
10	(c) Space shall	<del>be provi</del> e	ded for: Each facility shall provide:
11	(1)	chartin	ng, storage of supplies and personal effects of staff; an area for charting;
12	(2)	the sto	rage of resident care equipment; storage provisions for personal effects of staff;
13	(3)	housek	seeping equipment and cleaning supplies; storage areas for supplies and resident care
14		equipn	nent;
15	(4)	storage	e of test reagents and disinfectants distinct from medication; storage area(s) for housekeeping
16		equipn	nent and cleaning supplies;
17	(5)	locked	medication storage and preparation; and a medication preparation area with a counter, a sink
18		trimme	ed with valves that can be operated without hands, locked medication storage, and a double
19		locked	narcotic storage area under visual control of staff. If the sink is equipped with blade handles,
20		the bla	ade handles shall not be less than four inches in length. If the sink faucet depends on the
21		<u>buildir</u>	ng electrical service for operation, the faucet must have an emergency power source or battery
22		backup	capability. If the faucet has battery operated sensors, the facility shall have a maintenance
23		policy	to keep extra rechargeable or non-rechargeable batteries on premises for the faucets;
24	(6)	drugs requiring refrigeration. They may be stored in a separate locked box in the refrigerator or in	
25		a locks	able drug only refrigerator, capable of maintaining a temperature range of 36 degrees F (2
26		degree	s C) to 46 degrees F (8 degrees C). The storage and accountability of controlled substances
27		<del>shall b</del>	e in accordance with the North Carolina Controlled Substances Act, Article 5 of Chapter 90
28		of the	General Statutes. a lockable refrigerator for drug storage only or a separate locked box in a
29		facility	refrigerator. The refrigerator must be capable of maintaining a temperature range of 36
30		degree	s F (2 degrees C) to 46 degrees F (8 degrees C);
31	<u>(7)</u>	a kitch	en with:
32		<u>(A)</u>	a refrigerator;
33		<u>(B)</u>	a cooking appliance ventilated to the outside;
34		<u>(C)</u>	a 42-inch minimum double-compartment sink and domestic dishwashing machine capable
35			of sanitizing dishes with 160 degrees F water; and
36		<u>(D)</u>	storage space for non-perishables;
37	(8)	a senai	rate dining area measuring not less than 20 square feet ner resident hed:

I	<u>(9)</u>	a recreational and social activities area with not less than 150 square feet of floor area exclusive of		
2		corridor traffic;		
3	<u>(10)</u>	a nurses'calling system shall be provided:		
4		(A) in each resident bedroom for each resident bed. The call system activator shall be such that		
5		they can be activated with a single action and remain on until deactivated by staff at the		
6		point of origin. The call system activator shall be within reach of a resident lying on the		
7		bed. In rooms containing two or more call system activators, indicating lights shall be		
8		provided at each calling station;		
9		(B) nurses' calling systems which provide two-way voice communication shall be equipped		
10		with an indicating light at each calling station which lights and remains lighted as long a		
11		the voice circuit is operating;		
12		(C) a nurses' call emergency activator shall be proved at each residents' use toilet fixture, bath		
13		and shower. The call system activator shall be accessible to a resident lying on the floo		
14		<u>and</u>		
15		(D) calls shall register with the floor staff and shall activate a visible signal in the corridor a		
16		the resident's door. In multi-corridor units, additional visible signals shall be installed a		
17		corridor intersections;		
18	<u>(11)</u>	heating and air conditioning equipment that can maintain a temperature range between 68 degree		
19		and 80 degrees Fahrenheit, even upon loss of utility power.		
20	(d) Kitchen and	l dining areas shall have:		
21	(1)	<del>a refrigerator;</del>		
22	(2)	a cooking unit ventilated to the outside;		
23	(3)	a 42 inch minimum double compartment sink and domestic dishwashing machine capable of		
24		sanitizing dishes with 160 degrees F. water;		
25	(4)	dining space of 20 square feet per resident; and		
26	(5)	storage space for non-perishables.		
27	(e) Other areas	shall include:		
28	(1)	a minimum of 150 square feet exclusive of corridor traffic for recreational and social activities;		
29	(2)	an audible and accessible call system furnished in each resident's room and bathroom; and		
30	(3)	heating and air cooling equipment to maintain a comfort range between 68 degrees and 80 degrees		
31		Fahrenheit.		
32				
33	History Note:	Authority G.S. 131E-202;		
34		Eff. June 1, 1991;		
35		Amended Eff. February 1, <del>1995.</del> <u>1995:</u>		
36		Readopted Eff. October 1, 2021.		