| 1 | 10A NCAC 13K .1114 is proposed for readoption with substantive changes as follows: |
|----|--|
| 2 | |
| 3 | 10A NCAC 13K .1114 PLUMBING |
| 4 | (a) The water supply shall be designed, constructed and protected so as to assure that a safe, potable and adequate |
| 5 | water supply is available for domestic purposes in compliance with the North Carolina State Building Code. |
| 6 | (b) All plumbing in the residence or unit shall be installed and maintained in accordance with the North Carolina |
| 7 | State Plumbing Code. All plumbing shall be maintained in good repair and free of the possibility of backflow and |
| 8 | backsiphonage, through the use of vacuum breakers and fixed air gaps, in accordance with state and local codes. |
| 9 | (c) For homes hospice residential facilities with five or more residents, a 50-gallon quick recovery water heater is |
| 10 | required. For homes hospice residential facilities with fewer than five residents, a 40-gallon quick recovery water |
| 11 | heater is required. |
| 12 | |
| 13 | History Note: Authority G.S. 131E-202; |
| 14 | Eff. June 1, 1991. <u>1991;</u> |
| 15 | Readopted Eff. October 1, 2021. |