

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL049004	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED C 12/04/2014
--	--	---	---

NAME OF PROVIDER OR SUPPLIER ROSEWOOD ASSISTED LIVING	STREET ADDRESS, CITY, STATE, ZIP CODE 3134 HARMONY HIGHWAY HARMONY, NC 28634
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	<p>Initial Comments</p> <p>This is a Report of a Complaint Investigation conducted by Greg Cates on Decmber 4, 2014.</p> <p>The Complaint alleged that the water temperatures were not being maintained within the allowable range of 110 -116 degrees Fahrenheit and there were large fluctuations in temperature throughout the building.</p> <p>Based on information gathered from our files, the Facility was first licensed or submitted for licensure on or about October 1, 1964 with Fifty-Four (54) Resident Beds. Based on this information, the facility is required to meet the 1971 Minimum and Desired Standards and Regulations for the Licensing of Homes for the Aged and Infirm, applicable portions of the 2005 Licensing of Adult Care Homes of Seven or More Beds, and the 1967 North Carolina State Building Code Section 516(c)- Institutional Buildings.</p> <p>The Complaint was substantiated.</p>	C 000		
C 195	<p>Hot Water System</p> <p>SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS</p> <p>(d) The hot water system shall be of such size to provide an adequate supply of hot water to the kitchen, bathrooms, laundry, housekeeping closets and soil utility room. The hot water temperature at all fixtures used by residents shall be maintained at a minimum of 100 degrees F (38 degrees C) and shall not exceed 116 degrees F (46.7 degrees C).</p> <p>(k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities.</p>	C 195		

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL049004	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED C 12/04/2014
--	--	---	---

NAME OF PROVIDER OR SUPPLIER ROSEWOOD ASSISTED LIVING	STREET ADDRESS, CITY, STATE, ZIP CODE 3134 HARMONY HIGHWAY HARMONY, NC 28634
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 195	<p>Continued From page 1</p> <p>This Rule is not met as evidenced by: 1- Based on observations made at the time of the December 4, 2014 Biennial Construction Survey, the facility failed to ensure that the water temperature is being maintained within the required temperature range of 100- 116 degrees Fahrenheit. This deficiency affects all residents, staff, and visitors who may require hot water for bathing or washing of hands.</p> <p>Findings include: a- The temperatures in the following locations registered below the required minimum temperature: 1- 94 degrees Fahrenheit in the shared bathroom between Rooms 3 and 4. 2- 98 degrees Fahrenheit in the Tub/ Shower Room on Front Hall. 3- 98 degrees Fahrenheit in the shared bathroom between Rooms 9 and 10. 4- 90 degrees Fahrenheit in the shared bathroom between Rooms 15 and 16. 5- 94 degrees Fahrenheit in the shared bathroom between Rooms 17 and 18. 6- 94 degrees Fahrenheit in the Tub/ Shower Room on the Back Hall. 7- 90 degrees Fahrenheit in the shared bathroom between Rooms 19 and 20. 8- 88 degrees Fahrenheit in the shared bathroom between Rooms 21 and 22. 9- 92 degrees Fahrenheit in the shared bathroom between Rooms 23 and 24.</p>	C 195		