

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/25/2015
FORM APPROVED
OMB NO. 0938-0391

| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 345428 | (X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____ | (X3) DATE SURVEY COMPLETED 06/17/2015 |
|---|---|--|---|---|
| NAME OF PROVIDER OR SUPPLIER THE LAURELS OF SALISBURY | | STREET ADDRESS, CITY, STATE, ZIP CODE 215 LASH DRIVE SALISBURY, NC 28147 | | |
| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETION DATE |
| K 000 | <p>INITIAL COMMENTS</p> <p>This Life Safety Code(LSC) survey was conducted as per The Code of Federal Register at 42CFR 483.70(a); using the 2000 Existing Health Care section of the LSC and its referenced publications. This building is Type V(III) construction, one story, with a complete automatic sprinkler system utilizing special locking. In the exit conference all deficiencies noted were discussed with administration.</p> <p>At time of survey the: Total Certified Bed Count = 60 Census = 54</p> <p>There were no LSC deficiencies determined during the survey.</p> | K 000 | | |
| LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | | TITLE | | (X6) DATE |

Electronically Signed

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.