

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL064035</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/24/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>HUNTER HILL ASSISTED LIVING</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>891 NOELL LANE</b> <b>ROCKY MOUNT, NC 27804</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments  Report of a Biennial Follow Up Construction Survey by Suzanna Fay conducted on January 24, 2024.  There are deficiencies cited in the Biennial Construction Survey that remain to be corrected.	{C 000}		
{C 101}	Existing Licensed Fac- No less than '71 Rules  SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost;  This Rule is not met as evidenced by: 1. Observations revealed that the facility does not meet code requirements in effect at the time of construction, change in service or bed count, addition, renovation or alteration. Special locking is allowed in buildings protected throughout by an automatic fire detection system or automatic sprinkler system.  Findings on January 24, 2024:	{C 101}		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>HAL064035</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: <b>01</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>R</b> <b>01/24/2024</b>
NAME OF PROVIDER OR SUPPLIER  <b>HUNTER HILL ASSISTED LIVING</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>891 NOELL LANE</b> <b>ROCKY MOUNT, NC 27804</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
{C 101}	Continued From page 1  a. At the time of the survey, an electromagnetic locking system has been installed, but is currently not in use. There was not fire detection in the resident bathrooms.	{C 101}			