

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL092-805	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/25/2018
--	--	--	--

NAME OF PROVIDER OR SUPPLIER LIVING WITH AUTISM, INC	STREET ADDRESS, CITY, STATE, ZIP CODE 2817 TOBERMORY LANE RALEIGH, NC 27606
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

V 000	<p>INITIAL COMMENTS</p> <p>An annual survey was completed on 7/25/18. A deficiency was cited.</p> <p>This facility is licensed for the following service category: 10A NCAC 27G .5600C Supervised Living for Adults with Developmental Disabilities</p>	V 000	<p>DHSR-Mental Health</p> <p>AUG 22 2018</p> <p>Lic. & Cert. Section</p>	
V 752	<p>27G .0304(b)(4) Hot Water Temperatures</p> <p>10A NCAC 27G .0304 FACILITY DESIGN AND EQUIPMENT</p> <p>(b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors.</p> <p>(4) In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit.</p> <p>This Rule is not met as evidenced by: Based on observation and interview the facility failed to ensure water temperatures maintained between 100-116 degrees Fahrenheit. The findings are:</p> <p>Observation on 7/25/18 at 1:30 PM revealed water temperature in the kitchen and three client bathrooms revealed temperatures between 86-88 degrees Fahrenheit.</p> <p>During interview with the Qualified Professional and the Home Managers they stated the following: -Had been having problems maintaining the water temperatures in last few months. -The water was "too high or too low", so they have turned it up and down to get the right</p>	V 752	<p>LWA: GH manager will regulate temp. from water heater daily with staff documentation.</p> <p>Home warranty is notified for an appt to replace if needed.</p>	

Division of Health Service Regulation LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
--	-------	-----------