


Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL083-054	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R 12/14/2018
--	---	---	---

NAME OF PROVIDER OR SUPPLIER SCOTCHFAIR #2	STREET ADDRESS, CITY, STATE, ZIP CODE 13880 FRANCIS STREET GIBSON, NC 28343
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

V 000	<p>INITIAL COMMENTS</p> <p>An annual and follow up survey was completed on December 14, 2018. A deficiency was cited.</p> <p>This facility is licensed for the following service category: 10A NCAC 27G .5600C Supervised Living for Adults with Developmental Disabilities.</p>	V 000	<div style="border: 1px solid black; padding: 5px; text-align: center;"> <p>RECEIVED</p> <p><small>By DHSR - Mental Health Lic. & Cert. Section at 8:35 am, Jan 14, 2019</small></p> </div>	
V 752	<p>27G .0304(b)(4) Hot Water Temperatures</p> <p>10A NCAC 27G .0304 FACILITY DESIGN AND EQUIPMENT</p> <p>(b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors.</p> <p>(4) In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit.</p> <p>This Rule is not met as evidenced by: Based on observation and interview, the facility water temperatures were not maintained between 100-116 degrees Fahrenheit in areas where clients were exposed to hot water. The findings are:</p> <p>Observations on 12/13/18 between 10:00am and 10:30am revealed: -Kitchen sink water temperature read 121 degrees Fahrenheit. -Hall bathroom water temperature read 120 degrees Fahrenheit in the sink.</p> <p>Interview on 12/13/18 the Group Home Manager stated: -He was not aware the water temperatures were too hot.</p>	V 752		

Division of Health Service Regulation LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE 	TITLE Administrator - Lumberton Unit	(X6) DATE 1/9/19
--	---	---------------------

**Scotchfair #2
13880 Francis Street
Gibson, NC 28342
MLH 083-054**

Scotchfair #2 Plan of Correction

V752 Complete Date: January 9, 2019

The facility will keep its grounds maintained in a safe, clean, attractive and orderly manner. The facility will maintain the water temperature between 105-110 degrees Fahrenheit.

1. The staff will complete daily water temperature checks with any variances being documented on the water variance form for 14 consecutive days. The form will be turned into the Maintenance Supervisor. The QP, Home Manager, and Maintenance Coordinator will increase water temperature checks to twice a month for three consecutive months to ensure water temperature is safe.
2. The staff will be re in-serviced on how to check and document the water temperature in the kitchen and bathroom to ensure a safe environment for the individuals.



RHA Health Services
2003 Godwin Ave. Suite A1
Lumberton, NC 28358
Phone: 910-739-1468
Fax: 910-739-6134
Nurse Fax: 910-887-2511

FAX TRANSMISSION

CONFIDENTIAL HEALTH INFORMATION ENCLOSED

• • • • •

To:	Pam Bridger	Fax:	919-715-8078
From:	Tammie Hollingsworth	Date:	1/14/19
Re:	Plan of Correction	Pages:	(Including Cover) 3
CC:			
Urgent		For Review	As Requested
		Please Reply	Please Recycle

Additional Comments: Scoter Fair 2 Plan of Correction
(RHA Health Services NC, LLC)

Confidentiality Note: The enclosed facsimile transmission contains confidential medical record information. This information has been disclosed to the recipient identified above and is protected by State and Federal law. Those laws limit your ability to further disclose this confidential medical information without the prior written consent of the patient/client and his/her legal guardian or unless otherwise permitted by State and Federal law. If you are not the intended recipient, you are hereby notified that any USE, disclosure, copying, distribution, or OTHER action taken WITHOUT RESPECT TO the contents of these documents is strictly prohibited. If you have received this information in error, please notify the sender immediately and arrange for the return or destruction of these documents.