

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL053-076	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R 08/12/2019
--	---	---	---

NAME OF PROVIDER OR SUPPLIER I INNOVATIONS, INC - 5023 VALLEY VIEW	STREET ADDRESS, CITY, STATE, ZIP CODE 5023 VALLEY VIEW SANFORD, NC 27330
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 000	<p>INITIAL COMMENTS</p> <p>An annual and follow-up survey was completed on August 12, 2019. There was a deficiency cited.</p> <p>This facility is licensed for the following service category: 10A NCAC 27G. 5600A Supervised Living for Adults with Mental Illness</p>	V 000		
V 114	<p>27G .0207 Emergency Plans and Supplies</p> <p>10A NCAC 27G .0207 EMERGENCY PLANS AND SUPPLIES</p> <p>(a) A written fire plan for each facility and area-wide disaster plan shall be developed and shall be approved by the appropriate local authority.</p> <p>(b) The plan shall be made available to all staff and evacuation procedures and routes shall be posted in the facility.</p> <p>(c) Fire and disaster drills in a 24-hour facility shall be held at least quarterly and shall be repeated for each shift. Drills shall be conducted under conditions that simulate fire emergencies.</p> <p>(d) Each facility shall have basic first aid supplies accessible for use.</p> <p>This Rule is not met as evidenced by: Based on record review and interview the facility failed to conduct fire and disaster drills on each shift at least quarterly. The findings are:</p> <p>Review on 8/9/19 of the facility's fire and disaster drills record revealed: -Fire drills were conducted on the following dates and shifts: -1/16/19, 3/9/19, 5/10/19, 7/11/19, 8/5/19 -</p>	V 114		

Division of Health Service Regulation LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
--	-------	-----------

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL053-076	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R 08/12/2019
--	---	---	---

NAME OF PROVIDER OR SUPPLIER I INNOVATIONS, INC - 5023 VALLEY VIEW	STREET ADDRESS, CITY, STATE, ZIP CODE 5023 VALLEY VIEW SANFORD, NC 27330
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 114	<p>Continued From page 1</p> <p>2nd shift</p> <p>-Disaster drills were conducted on the following dates and shifts: -2/11/19, 4/5/19, 6/17/19, 8/5/19 - 2nd shift</p> <p>-No fire and disaster drills conducted on 1st and 3rd shift.</p> <p>-Fire and disaster drills were not conducted on each shift at least quarterly.</p> <p>Interview on 8/12/19 with the President revealed:</p>	V 114		