Division of Health Service Regulation STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION AND PLAN OF CORRECTION (X3) DATE SURVEY IDENTIFICATION NUMBER: A. BUILDING: COMPLETED R B. WING MHL043-012 08/11/2021 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE 141 EAST JACKSON STREET JACKSON STREET GROUP HOME COATS, NC 27521 SUMMARY STATEMENT OF DEFICIENCIES (X4) ID PROVIDER'S PLAN OF CORRECTION ID (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX (EACH CORRECTIVE ACTION SHOULD BE PREFIX COMPLETE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG CROSS-REFERENCED TO THE APPROPRIATE TAG DATE DEFICIENCY) V 000 INITIAL COMMENTS V 000 An annual and follow up survey was completed on 8-11-21. Deficiencies were cited. This facility is licensed for the following service category: 10A NCAC 27G.5600C Supervised Living for Adults with Developmental Disability. V 119 27G .0209 (D) Medication Requirements V 119 10A NCAC 27G .0209 MEDICATION DHSR - Mental Health REQUIREMENTS (d) Medication disposal: (1) All prescription and non-prescription SEP 1 5 2021 medication shall be disposed of in a manner that guards against diversion or accidental ingestion. (2) Non-controlled substances shall be disposed Lic. & Cert. Section of by incineration, flushing into septic or sewer system, or by transfer to a local pharmacy for destruction. A record of the medication disposal shall be maintained by the program. Documentation shall specify the client's name. medication name, strength, quantity, disposal date and method, the signature of the person disposing of medication, and the person witnessing destruction. (3) Controlled substances shall be disposed of in accordance with the North Carolina Controlled Substances Act, G.S. 90, Article 5, including any subsequent amendments. (4) Upon discharge of a patient or resident, the remainder of his or her drug supply shall be disposed of promptly unless it is reasonably expected that the patient or resident shall return to the facility and in such case, the remaining drug supply shall not be held for more than 30 calendar days after the date of discharge.

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

3KRR

17/0-1

(X6) DATE

PRINTED: 08/25/2021 FORM APPROVED

Division of Health Service Regulation (X3) DATE SURVEY (X2) MULTIPLE CONSTRUCTION (X1) PROVIDER/SUPPLIER/CLIA STATEMENT OF DEFICIENCIES COMPLETED IDENTIFICATION NUMBER: AND PLAN OF CORRECTION A. BUILDING: _ R 08/11/2021 B. WING_ MHL043-012 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 141 EAST JACKSON STREET JACKSON STREET GROUP HOME **COATS, NC 27521** PROVIDER'S PLAN OF CORRECTION SUMMARY STATEMENT OF DEFICIENCIES (EACH CORRECTIVE ACTION SHOULD BE COMPLETE (X4) ID (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX DATE CROSS-REFERENCED TO THE APPROPRIATE PREFIX REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG DEFICIENCY) V 119 V 119 Continued From page 1 This Rule is not met as evidenced by: Based on record review, observations and interviews, the facility failed to ensure medications were disposed of in a manner that guards against diversion or accidental ingestion for two of four clients (#1 and #3). The findings Review on 8/10/21 of client #1's record revealed: -Date of Admission: 9/25/14 -Diagnoses: Mild Mental Retardation, Congenital, Hydrocephalus, Leukodystrophy, Neurogenic bladder, Vascular Insufficiency, Acne, Spasticity, Bipolar disorder Observation on 8/10/21 at 10:30am of client #1's medications on site revealed the following: - Clindamycin Gel 1% dispensed 1/15/20 with expiration date of 1/14/21 - Polyeth glyc pow 3350 dispensed 12/06/18 with expiration date of 12/15/19 - Ondansetron 4 milligram (mg) tablet dispensed 5/26/20 with expiration date of 5/25/21 Review on 8/10/21 of client #3's record revealed: -Date of Admission: 2/22/20 -Diagnoses: Schizophrenia Paranoid, Mild Intellectual Disabilities, Bilateral Cataracts Observation on 8/10/21 at 11:38am of client #3's medications on site revealed the following: - GS sunscreen Lot SPF 15 For Coppertone dispensed 1/30/18 with expiration date of 1/29/19 - Poleth glyc Pow 3350 dispense 12/6/18 with expiration date of 12/5/19

-Ventolin HFA 30 microgram (mcg) dispense 4/16/19 with expiration date of 4/15/20

3KRR11

PRINTED: 08/25/2021 FORM APPROVED

Division of Health Service Regulation STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION (X3) DATE SURVEY AND PLAN OF CORRECTION **IDENTIFICATION NUMBER:** A. BUILDING: _ COMPLETED R B. WING MHL043-012 08/11/2021 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE 141 EAST JACKSON STREET JACKSON STREET GROUP HOME COATS, NC 27521 SUMMARY STATEMENT OF DEFICIENCIES (X4) ID PROVIDER'S PLAN OF CORRECTION PREFIX (EACH DEFICIENCY MUST BE PRECEDED BY FULL (X5) COMPLETE (EACH CORRECTIVE ACTION SHOULD BE PREFIX TAG REGULATORY OR LSC IDENTIFYING INFORMATION) TAG CROSS-REFERENCED TO THE APPROPRIATE DATE DEFICIENCY) V 119 | Continued From page 2 V 119 Interview on 8/10/21 staff #1 stated: -She had not looked at the expiration dates -She didn't know how often the house manager checked the medication closet - The nurse would come over monthly, but not sure if the nurse checked the medication closet monthly, but "she should" Interview on 8/10/21 staff #2 stated: - She had not been in the medication closet, she is not a medication technician yet - She had seen the nurse come, but was not sure how often she would come over to the home. Interview on 8/10/21 the House Manager stated: - She had acquired the home a couple of months ago - She had disposed of expired medication that were previously in the medication closet - The nurse had completed assessments every month, but didn't know sure if the nurse checked the medication closet monthly, but "she should" V 752 27G .0304(b)(4) Hot Water Temperatures V 752 10A NCAC 27G .0304 FACILITY DESIGN AND **EQUIPMENT** (b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors. (4)In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit.

Division of Health Service Regulation

This Rule is not met as evidenced by:

PRINTED: 08/25/2021 FORM APPROVED Division of Health Service Regulation (X3) DATE SURVEY (X2) MULTIPLE CONSTRUCTION (X1) PROVIDER/SUPPLIER/CLIA STATEMENT OF DEFICIENCIES COMPLETED IDENTIFICATION NUMBER: AND PLAN OF CORRECTION A. BUILDING: _ R 08/11/2021 B. WING MHL043-012 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 141 EAST JACKSON STREET JACKSON STREET GROUP HOME **COATS, NC 27521** PROVIDER'S PLAN OF CORRECTION (X5) COMPLETE SUMMARY STATEMENT OF DEFICIENCIES (EACH CORRECTIVE ACTION SHOULD BE (X4) ID (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX DATE PREFIX CROSS-REFERENCED TO THE APPROPRIATE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG DEFICIENCY) V 752 V 752 | Continued From page 3 Based on observation and interview, the facility water temperatures were not maintained between 100-116 degrees Fahrenheit in areas where clients were exposed to hot water. The findings are: Observation on 8/10/21 at 2:15pm revealed: - The kitchen sink hot water temperature was 90 degrees Fahrenheit. - The bathroom sink used by client #2 and client #4 had a water temperature of 92 degrees Fahrenheit. Interview on 8/10/21 staff #1 stated: - The water takes a long time to get warm. - Third shift usually check the water temperature. - Did not know where the water temperature documentation was kept. Interview on 8/10/21 the House Supervisor - Water temperature was checked daily - She didn't remember any of the past water temperatures - Water temperature documentation was taken to the main office monthly - She was unable to find the water temperature documentation V 774 V 774 27G .0304(d)(7) Minimum Furnishings 10A NCAC 27G .0304 FACILITY DESIGN AND **EQUIPMENT** (d) Indoor space requirements: Facilities licensed prior to October 1, 1988 shall satisfy the minimum

Division of Health Service Regulation STATE FORM

square footage requirements in effect at that time. Unless otherwise provided in these Rules, residential facilities licensed after October 1, 1988 shall meet the following indoor space

3KRR11

PRINTED: 08/25/2021 FORM APPROVED

Division of Health Service Regulation STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION (X3) DATE SURVEY AND PLAN OF CORRECTION **IDENTIFICATION NUMBER:** A. BUILDING: COMPLETED R B. WING MHL043-012 08/11/2021 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE 141 EAST JACKSON STREET JACKSON STREET GROUP HOME **COATS, NC 27521** SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION ID (X5) COMPLETE (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX PREFIX (EACH CORRECTIVE ACTION SHOULD BE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG CROSS-REFERENCED TO THE APPROPRIATE DATE DEFICIENCY) V 774 Continued From page 4 V 774 requirements: (7) Minimum furnishings for client bedrooms shall include a separate bed, bedding, pillow, bedside table, and storage for personal belongings for each client. This Rule is not met as evidenced by: Based on observation and interviews, the facility failed to assure a designated client bedroom had minimum furnishings. The findings are: Observation on 8/10/21 at 2:40pm of a vacant client bedroom revealed no bed, mattress or bedside table was in the room. Interview on 8/10/21 staff #1 stated: -The furnishings for the room left with the last client that resided in the room. - Furniture was kept in storage or at the office, she was not sure where Interview on 8/10/21 the House Manager stated: - The client that left owned that furniture and took it with him when he left. - The company will either buy new furniture or allow the client to bring there own furniture. Interview on 8/11/21 the Administrator stated: - The company will buy new furnishings when a new client is identified.

Jackson Street Group Home Plan of Correction

For

Annual and follow up Survey completed 8-11-21

V 119 27G .0209 (D) Medication Requirements

The facility will ensure medications are disposed of in a manner that guards against diversion or accidental ingestion.

Nursing will in-service staff on ensuring person supported # 1 and #3 medications are disposed of in a manner that guards against diversion or accidental ingestion.

The IDT will monitor and ensure medications are disposed of in a manner that guards against diversion or accidental ingestion as evidenced by Nursing completing monthly Nursing Assessments two times per month for three consecutive months and QP/Residential Team Lead reviewing medication cabinet once a month for 3 consecutive months.

Target Date: 11/11/2021

V 752 27G .0304(b)(4) Hot Water Temperatures

The facility water temperatures will be maintained between 100-116 degrees Fahrenheit in areas where clients are exposed to hot water.

QP and Residential Team Lead will in-service staff on checking and documenting the water temperatures where clients were exposed to hot water. QP and Residential Team Lead will complete work order for the kitchen sink hot water temperature being 90 degrees Fahrenheit, the bathroom sink used by client #2 and client #4 had a water temperature of 92 degrees Fahrenheit.

The IDT will monitor that the facility water temperatures are maintained between 100-116 degrees Fahrenheit in areas where clients are exposed to hot water as evidenced by the water temperature monitoring form being submitted to the Administrator on the 1st and the 15th of every month for review and follow up for 3 consecutive months.

Target Date: 11/11/2021

V 774 27G .0304(d)(7) Minimum Furnishings

The facility will provide designated client bedroom with minimum furnishings including a separate bed, bedding, pillow, bedside table, and storage for personal belongings for each client.

QP, Residential Team Lead, and Administrator will ensure vacant client bedroom has minimum furnishings.

The IDT will ensure the minimum furnishings including a separate bed, bedding, pillow, bedside table, and storage for personal belongings for each client is ordered and present in the vacant client bedroom.

Target Date: 11/11/2021