

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL026-760	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/12/2022
--	---	---	---

NAME OF PROVIDER OR SUPPLIER FAYETTEVILLE TREATMENT CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 418 PERSON STREET SUITE 103 FAYETTEVILLE, NC 28301
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 000	<p>INITIAL COMMENTS</p> <p>An annual survey was completed on May 12, 2022. A deficiency was cited.</p> <p>This facility is licensed for the following service category: 10A NCAC 27G .3600 Outpatient Opioid Treatment.</p> <p>This facility has a current census of 387. The survey sample consisted of audits of 20 current clients.</p>	V 000		
V 752	<p>27G .0304(b)(4) Hot Water Temperatures</p> <p>10A NCAC 27G .0304 FACILITY DESIGN AND EQUIPMENT</p> <p>(b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors.</p> <p>(4) In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit.</p> <p>This Rule is not met as evidenced by: Based on observation and interview, the facility water temperatures were not maintained between 100-116 degrees Fahrenheit in areas where clients were exposed to hot water. The findings are:</p> <p>Observation on 05/12/22 at approximately 11:17am revealed: - The hot water temperature in the client designated bathroom was 120 degrees Fahrenheit.</p> <p>Interview on 05/12/22 the Program Director</p>	V 752		

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL026-760	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/12/2022
--	---	---	---

NAME OF PROVIDER OR SUPPLIER FAYETTEVILLE TREATMENT CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 418 PERSON STREET SUITE 103 FAYETTEVILLE, NC 28301
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 752	Continued From page 1 stated: - The water heater had just been repaired. - She was aware the water temperature was required to be between 100 to 116 degrees Fahrenheit. - She would ensure the water temperature was monitored.	V 752		