

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL026-760	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/12/2022
NAME OF PROVIDER OR SUPPLIER FAYETTEVILLE TREATMENT CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 418 PERSON STREET SUITE 103 FAYETTEVILLE, NC 28301		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 000	INITIAL COMMENTS An annual survey was completed on May 12, 2022. A deficiency was cited. This facility is licensed for the following service category: 10A NCAC 27G .3600 Outpatient Opioid Treatment. This facility has a current census of 387. The survey sample consisted of audits of 20 current clients.	V 000		
V 752	27G .0304(b)(4) Hot Water Temperatures 10A NCAC 27G .0304 FACILITY DESIGN AND EQUIPMENT (b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors. (4) In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit. This Rule is not met as evidenced by: Based on observation and interview, the facility water temperatures were not maintained between 100-116 degrees Fahrenheit in areas where clients were exposed to hot water. The findings are: Observation on 05/12/22 at approximately 11:17am revealed: - The hot water temperature in the client designated bathroom was 120 degrees Fahrenheit. Interview on 05/12/22 the Program Director	V 752	Repairs to the water heater were completed on 5/11/2022. Water heater was replaced, enclosed is a copy of the landlord's invoice from: ABC Plumbing Company PO Box 53052 Fayetteville, NC 28305 State license 5977 Regular checks will be conducted to ensure the hot water remains hot, any indication that there is a change in the temperature will be reported to the landlord and corporate office for immediate	5/11/2022


TERRI SENKOW L

Digitally signed by TERRI SENKOW L
DN: c=US, o=U.S. Government, ou=Department of Justice, ou=DEA, ou=Diversion Control, ou=E-Commerce, ou=CSOS, ou=FL, serialNumber=N12503202299, cn=TERRI SENKOW L
Date: 2022.05.20 08:45:56 -04'00'

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE



Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: MHL026-760	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/12/2022
--	---	---	---

NAME OF PROVIDER OR SUPPLIER FAYETTEVILLE TREATMENT CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 418 PERSON STREET SUITE 103 FAYETTEVILLE, NC 28301
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 752	Continued From page 1 stated: - The water heater had just been repaired. - She was aware the water temperature was required to be between 100 to 116 degrees Fahrenheit. - She would ensure the water temperature was monitored.	V 752		

INVOICE

ABC PLUMBING COMPANY

P.O. BOX 53052
 FAYETTEVILLE, NC 28305
 PH. 910-323-4060

STATE LICENSE NUMBER 5977

INVOICE NUMBER:

27526

INVOICE DATE:

5/13/2022

PAGE:

SOLD TO:
 ELMWOOD BUILDERS
 2919 BREEZEWOOD AVENUE
 SUITE # 200
 FAYETTEVILLE, NC 28303
 ATTN: TOMMY BRADFORD

SHIP TO:
 JOB: FAYETTEVILLE TREATMENT CENTER
 418 PERSON ST
 FAYETTEVILLE, NC

SHIP VIA
 SHIP DATE 5/13/2022
 DUE DATE
 TERMS

CUST. I.D.
 P.O. NUMBER
 P.O. DATE 05/12/2022
 OUR ORDER NO.
 SALESPERSON LEI

ITEM I.D. / DESC.	ORDERED	SHIPPED	UNIT	PRICE	NET	TX
LABOR			2	125.00	250.00T	
5/11/2022 PLUMBERS ASSESSED NO HOT WATER. PLUMBERS FOUND WATER HEATER IS RUSTED OUT AND NEEDS TO BE REPLACED.						
WATER HEATER	10 GALLON ELECTRIC			591.50	591.50T	
PARTS				50.00	50.00T	
LABOR				400.00	400.00T	
	Sales Tax			7.00%	90.41	

PLEASE PAY FROM THIS INVOICE NO OTHER COPIES WILL BE SENT. PAST DUE INVOICES WILL BE SUBJECT TO A 1.5% LATE CHARGE. A 4% CHARGE WILL BE ADDED TO BILLS OVER \$500.00 FOR CREDIT CARD PAYMENTS.

SUBTOTAL :	
TAX :	
PAYMENT :	\$1,381.91
TOTAL :	