

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>MHL071-039</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>10/30/2025</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER  <b>KEELEAN HOME</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>2240 SLOOP POINT ROAD HAMPSTEAD, NC 28443</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 000	<p><b>INITIAL COMMENTS</b></p> <p>An annual survey was completed on October 30, 2025. A deficiency was cited.</p> <p>This facility is licensed for the following service category: 10A NCAC 27G .5600F Alternative Family Living.</p> <p>The facility is licensed for 2 and currently has a census of 2 clients. The survey sample consisted of audits of 2 current clients.</p>	V 000		
V 752	<p><b>27G .0304(b)(4) Hot Water Temperatures</b></p> <p><b>10A NCAC 27G .0304 FACILITY DESIGN AND EQUIPMENT</b></p> <p>(b) Safety: Each facility shall be designed, constructed and equipped in a manner that ensures the physical safety of clients, staff and visitors.</p> <p>(4) In areas of the facility where clients are exposed to hot water, the temperature of the water shall be maintained between 100-116 degrees Fahrenheit.</p> <p>This Rule is not met as evidenced by: Based on observation and interview, the facility water temperatures were not maintained between 100-116 degrees Fahrenheit in areas where clients were exposed to hot water. The findings are:</p> <p>Observation on 10/30/25 at approximately 11:00am revealed: -The hot water temperature at the kitchen sink was 122 degrees Fahrenheit.</p> <p>Interview on 10/30/25 the provider stated: - She would follow up to ensure the proper range</p>	V 752		

Division of Health Service Regulation  
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE \_\_\_\_\_ TITLE \_\_\_\_\_ (X6) DATE \_\_\_\_\_

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>MHL071-039</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>10/30/2025</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER  <b>KEELEAN HOME</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>2240 SLOOP POINT ROAD HAMPSTEAD, NC 28443</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
V 752	Continued From page 1 of water temperature was maintained.	V 752		