

1 10A NCAC 15 .0907 is proposed for readoption with substantive changes as follows:

2

3 **10A NCAC 15 .0907 WARNING DEVICES**

4 (a) ~~All~~ Except in facilities designed for human exposure, all locations designated as high radiation ~~areas, areas~~ and  
5 entrances to such locations shall be equipped with easily observable warning lights that operate when, and only when,  
6 radiation is being produced. Facilities designed for human exposure shall be equipped with easily observable warning  
7 lights outside the entrances to high radiation areas that operate when, and only when, radiation is being produced.

8 (b) Except in facilities designed for human exposure, each high radiation area shall have an audible warning device  
9 which shall be activated for 15 seconds prior to the possible creation of such high radiation area. This warning device  
10 shall be clearly discernible in all high radiation areas and all radiation areas.

11 (c) Barriers, temporary or otherwise, and pathways leading to high radiation areas shall be identified in accordance  
12 with Rule ~~1624.1601~~ of this Chapter.

13

14 *History Note: Authority G.S. 104E-7;*

15 *Eff. February 1, 1980;*

16 *Amended Eff. January 1, 1994;*

17 *Transferred and Recodified from 15A NCAC 11 .0907 Eff. February 1, ~~2015~~, 2015;*

18 *Readopted Eff. October 1, 2025.*